



Government Of West Bengal  
Office Of The Divisional Fire Officer, Darjeeling  
West Bengal Fire & Emergency Services  
Station Feeder Road, P.O & P.S Siliguri,  
District: Darjeeling, Pin - 734005

Memo no.: WBFES/NZ/FP/219/15

Date: 10-10-2023

**From:**  
Divisional Fire Officer, Darjeeling  
West Bengal Fire & Emergency Services

**To:** TECHNO INDIA GROUP WORLD SCHOOL  
HIMANCHAL VIHAR, P.S.- MATIGARA, DIST- DARJEELING

**Sub:** Issuance of Fire Safety Certificate for the G+3 storied Educational Building under group Educational in name of TECHNO INDIA GROUP WORLD SCHOOL at Himachal Bihar, Matigara, Darjeeling.

This is in reference to your application no. 0125189230500092 dated 06-10-2023 regarding the Issuance of Fire Safety Certificate for the G+3 storied Educational Building under group Educational in name of TECHNO INDIA GROUP WORLD SCHOOL at Himachal Bihar, Matigara, Darjeeling.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

**Recommendation:**

1. Driveway must be free from any type of obstruction for easy movement of Fire Appliances, No Parking board will be allowing on the driveway.
2. To eliminate the risk of Fire Hazards, good housekeeping for both inside and outside of the building will be strictly maintaining.
3. Arrangements shall have to be made for regular checking, testing and maintenance of all the Fire fighting installation in the building by a Licensee agency and to keep those in perfectly good working condition all the times and it should be shown in the register.
4. Adequate number of "NO SMOKING" boards should be displaying surrounding the premises.
5. Existing electrical wiring and installation of whole building should be carefully checking and maintenance regularly by a licensed electrician for any wear and tear at those, particularly wiring on false ceiling and ducts.
6. A Fire control room including a closed circuit T.V system and Fire alarm panel will have to be install, which observes all floor of the building.
7. Regular mock fire practices and evacuation drill should be conducted periodically by participation of all the occupants of the building and for this purpose a special crew should be formed.
8. The employees and security staff shall be conversant with installed Firefighting equipments of the building and to operate

The authenticity of this document can be verified by accessing the URL: [edistrict.wb.gov.in](http://edistrict.wb.gov.in) and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Issue Number : 0125189230500092.

Page : 1

**DIRECTOR**  
TECHNO INDIA GROUP  
WORLD SCHOOL  
Himachal Vihar, Siliguri

*attested  
Himanchal  
Gurosh*



*attested*

*Director*

in the event of Fire and Testing.

9. The notice and drawing of Fire fighting Installation and Evacuation from the entire floor of the building should be prepared and displayed at every conspicuous place of the building as per clause 5.5 of N.B code. Fire exit should be marked with fluorescent letter at every floor.

10. Directional sign of escape route should be displaced prominently (Auto glow type) at all conspicuous place of the building as per clause 5.5 of the N.B Code.

11. Transformer and switchgear room should be protecting with automatic CO2 or D.C.P. Fire extinguisher conforming I.S specification.

12. First Aid Firefighting system should be providing as per I.S specification.

13. All the Firefighting Extinguisher should be test once in a year.

14. If required the old Firefighting system should be replaced with new, the cables will be always laying in M.S conduit pipe continuously bonded to the earth.

15. Periodical flashing of water from the Fire Hydrants and Sprinkler pipeline should be making to maintain the efficient working performance of above mentioning system.

16. The Fire Safety audit to be conducted a regular interval and to be recorded in the Fire Prevention maintenance register.

17. A crew of trained Fireman under the experienced officer shall be depute and maintained round the clock for safety of the building.

18. All employees should be trained to operate the Firefighting equipment of the factory, that they can operate the same in case of exigency.

19. Mock fire drill and evacuation drill should be done periodically with participation of all officers personnel and security guards.

A register for the recording of Mock fire drill, evacuation drill, testing and checking of whole firefighting installation, electrical installation will be maintained & liable to produce the same to the authorized officer of this department on demand.

This certificate is valid for 3 year u/r 18 of WBFS ( Fire Prevention and Safety) Rules, 2003 and renewable after 3 year from date of issue failing which this shall be revoked automatically.

*Attested  
Malantra Ghosh*



*attested  
Dhiman Bhattacharya*

Signature valid  
Digitally Signed  
Name: DEBANKRASG  
Date: 10-Oct-2023 10:04  
Reason: Approved  
Location: West Bengal

Divisional Fire Officer, Darjeeling  
Division, Darjeeling  
West Bengal Fire & Emergency Services

**4** DIRECTOR  
TECHNO INDIA GROUP  
WORLD SCHOOL  
Himachal Vihar, Siliguri